



GENERAL CONSTRUCTION NOTES:

- 1). ALL CONCRETE SHALL BE CLASS "B"
- 2). CRUSHED STONE SHALL BE EXTENDED 6" ABOVE DRAIN OPENINGS IN HYDRANT BASE.
- 3). 4 1/2 " PUMPER NOZZLE TO FACE IN DIRECTION OF STREET OR ROAD UNLESS OTHERWISE SPECIFIED.
- 4). MINIMUM DEPTH IS TO BE 42 INCH COVER

NOTE:

SEE PADUCAH WATER STANDARD MATERIAL SECTION FOR FIRE HYDRANT MANUFACTURE AND MODEL AS REQUIRED BY PADUCAH WATER.

PADUCAH WATER CITY HYDRANT THREAD TYPE

- * 2 1/2 INCH HOSE NOZZLE
- NO. THREAD 6 , STYLE 60 DEGREE "V"
- * PAT. NO. AN250H / GASKET B4948
- * 4 1/2 INCH STEAMER NOZZLE THREAD IS TYPICAL NATIONAL STANDARD THREAD
- * COLOR TO BE SILVER
- PAINTED AS PER PADUCAH WATER MATERIALS SPEC

PADUCAH WATER COUNTY HYDRANT THREAD TYPE

- * 2 1/2 INCH HOSE NOZZLE AND 4 1/2 INCH STEAMER NOZZLE ARE BOTH NATIONAL STANDARD THREAD TYPE
- * COLOR TO BE RED
- PAINTED AS PER PADUCAH WATER MATERIALS SPEC